



Tammy Tengs <tammybuysland@gmail.com>

Driveway Approval letter

1 message

[REDACTED]
To: Tammy Tengs <tammybuysland@gmail.com>

Thu, Jan 11, 2024 at 3:47 PM


Begin forwarded message:

From: nst@frontiernet.net
Date: 4 June 2020 at 2:26:12 PM GMT-7
[REDACTED]
Subject: Approval
Reply-To: "nst@frontiernet.net" <nst@frontiernet.net>

[REDACTED]
We have received approval from Cal-Fire for your project. Very exciting news!! I have attached the approval letter signed by Joel and also a letter he has written and sent to the County, for your documentation. He mentioned that he will contact the County about this project and then it will be up to the County to review the plans and give us their plans check review comments. So, like we had mentioned before this could take up to a month or more seeing how things have slowed during this COVID-19 period. I will continue to keep you informed at where the project is at once we hear from the County.

Have a good day!
Stefanie

NST Engineering, Inc
[1495 Riverside Drive](#)
[Susanville, CA 96130](#)
(530) 257-5173
www.nstengineering.com

 **20200604141850.pdf**
314K

Complete the following information (2 pages):

Section A: State the specific section or sections for which an exception is requested.

1273.03 roadway grade
1276.01 setback for structure defensible space

Section B: State the factual circumstances supporting the need for exception. (Why you are unable to comply with the standard)

see attached letter

Section C: State the mitigation measure and details you propose that will meet the same practical effect as what is required by law.

see attached letter

JOEL GOLDMAN FIRE CAPTAIN 5/21/20
Received by (Print Name & Title) Date

JOEL GOLDMAN FIRE CAPTAIN
Approved by (Print Name & Title)


Approved by signature

**DEPARTMENT OF FORESTRY AND FIRE PROTECTION**

Lassen-Modoc Unit
697-345 Highway 36
Susanville, CA 93610
530-257-8520



June 04, 2020

Charles White
Building Services Director
555 Main Street
Quincy, CA 95971

RE: Exception Letter for
APN: 003-291-007
3566 Lake View Drive
Little Grass Valley, CA 95981

Mr. White,

I have conducted a site review of the following project. My recommendation for this project is to approve the attached "Exception Request".

Please review Section A on the "Exceptions" form attachment regarding California Code of Regulations, Title 14 Natural Resources, Division 1.5 Department of Forestry, Chapter 7-Fire Protection, Subchapter 2 SRA Fire Safer Regulations, Article 5:

- 1273.03 Grades, allow for twenty (20) percent grade providing road surface is paved.
- 1276.01 Setback for structure defensible space, allow for no less than fifteen (15) foot setback providing all exposed structure surfaces are non-combustible.

Please review Section(s) B and C attachments for the "Need for Exception" and "Mitigation measures for those Exceptions".

All other regulations of the 2020 SRA Fire Safe Regulations apply.

Respectfully,

A handwritten signature in blue ink, appearing to read "Joel Goldman".

Joel Goldman
Fire Captain Specialist
CAL FIRE
Lassen-Modoc Unit