State of California

Well Completion Report

Form DWR 188 Submitted 8/13/2021

WCR2021-010203

Owner's Well Number 1 | Date Work Began 03/08/2021 | Date Work Ended 03/12/2021

Local Permit Agency San Bernardino County DPH - Environmental Health Services Safe Drinking Water Permit Section

Secondary Permit Agency | Permit Number WP0036834 | Permit Date 03/08/2021

Well Owner (must remain confidential pursuant to Water Code 13752)

Name [redacted]

Mailing Address [redacted]

City [redacted] State CA Zip [redacted]

Planned Use and Activity

Activity New Well

Planned Use Water Supply Public

Well Location

Address 45484 Toy Truck TR

City Newberry Springs Zip 92365 County San Bernardino

Latitude 34 Deg. 52 Min. 12.0611 Sec. N | Longitude -116 Deg. 40 Min. 5.106 Sec. W

Dec. Lat. 34.870017 | Dec. Long. -116.668085

Vertical Datum | Horizontal Datum WGS84

Location Accuracy | Location Determination Method

APN 0532-102-56-0000

Township 09 N

Range 03 E

Section 16

Baseline Meridian San Bernardino

Ground Surface Elevation 1835

Elevation Accuracy 1 Ft

Elevation Determination Method Digital Aerial Photo

Borehole Information

Orientation Vertical | Specify

Drilling Method Direct Rotary | Drilling Fluid Bentonite

Total Depth of Boring 300 Feet

Total Depth of Completed Well 300 Feet

Water Level and Yield of Completed Well

Depth to first water 160 (Feet below surface)

Depth to Static Water Level 160 (Feet) | Date Measured 03/18/2021

Estimated Yield* 50 (GPM) | Test Type Bailing

Test Length 4 (Hours) | Total Drawdown (feet)

*May not be representative of a well's long term yield.

Geologic Log - Free Form

Depth from Surface Feet to Feet		Description
0	130	Coarse sand and gravel, layers of clay
130	230	Fine-medium sand, layers of clay
230	300	Coarse sand and gravel

Casings

Casing #	Depth from Surface Feet to Feet		Casing Type	Material	Casings Specificatons	Wall Thickness (inches)	Outside Diameter (inches)	Screen Type	Slot Size if any (inches)	Description
1	0	180	Blank	PVC	OD: 5.563 in. | SDR: 17 | Thickness: 0.327 in.	0.327	5.563			certalok
1	180	300	Screen	PVC	OD: 5.563 in. | SDR: 17 | Thickness: 0.327 in.	0.327	5.563	Milled Slots	1	certalok

Annular Material

Depth from Surface Feet to Feet		Fill	Fill Type Details	Filter Pack Size	Description
0	55	Cement	Other Cement	6 sk	pea gravel
55	300	Filter Pack	Other Gravel Pack	#5	birdseye

Other Observations:

Borehole Specifications

Depth from Surface Feet to Feet		Borehole Diameter (inches)
0	55	12.25
55	300	10

Certification Statement

I, the undersigned, certify that this report is complete and accurate to the best of my knowledge and belief

Name: RANDALL N WALLIS
Person, Firm or Corporation

P O BOX 1458 (Address) | BARSTOW (City) | CA (State) | 92312 (Zip)

Signed: *electronic signature received* (C-57 Licensed Water Well Contractor) | 08/13/2021 (Date Signed) | 515955 (C-57 License Number)

DWR Use Only

CSG #	State Well Number	Site Code	Local Well Number

				N	

Latitude Deg/Min/Sec

					W

Longitude Deg/Min/Sec

TRS:

APN: