

STATEMENT

TOM'S SEPTIC SYSTEMS
 Cont. Lic. #456116
 7740 Old Honcut
 OROVILLE, CALIFORNIA 95966-9374

DATE 12/17/02

(530) 533-6095

30 Happy Hollow
Oroville, Ca

TERMS: **SEPTIC INSPECTION REPORT**

PLEASE DETACH AND RETURN WITH YOUR REMITTANCE


\$ 350.00

DATE	INVOICE NUMBER / DESCRIPTION	CHARGES	CREDITS	BALANCE
------	------------------------------	---------	---------	---------

BALANCE FORWARD



		Ran hydro test on septic system for 30 min at 10 am system passed test no signs of leach field problems		
		Pumped out 1000 gal concrete septic tank, Septic TS on inlet and outlet of tank. No leaks in house, Tank and leach field in working condition at this time, but there is no guarantee on the life of a leach field.		250.00
		Inspection fee		100.00
				350.00



Inspected by Tom Thompson
 Cont. Lic # 456116
 12/17/02

TOM'S SEPTIC SYSTEMS

Thank You

PAY LAST AMOUNT IN THIS COLUMN